

KELINE

Certificate bundle

from independent testing
laboratories for Keline®
structured cabling



Keline® components Cat. 6_A , Cat. 7

- Installation cable, Category 6_A, 550 MHz, (B2_{ca}, D_{ca}, Outdoor)
- Installation cable, Category 7, 1000 MHz, (B2_{ca}, D_{ca})
- Keystone jack, patch panel, Category 6_A
- Keystone jack, HD, Category 6_A
- Patch cable, Category 6_A

FORCE Technology
FORCE Technology
FORCE Technology
GHMT
FORCE Technology

check if the certificate is not fake, created or edited in software.

**** ISO/IEC 11801:2017 (Ed.1.0)** - International standard defining the requirements for structured cabling
TIA-568.2-D:2018 - American national standard defining the requirements for structured cabling

Compliance Statement

No. 2023-113

Data communication cable, Category 6A

Company

KRUGEL EXIM spol. s r.o.
Pri majeri 13
831 06 Bratislava
Slovak Republic

Product description

Screened cable (U/FTP) characterised up to 500 MHz
Horizontal floor wiring cable, 100 Ω
4 individually foil screened twisted pairs
Flame retardant, halogen free

Product identification

Keline 10Giga 550MHz, STP 4x2xAWG23 Cat.6A, LSOH
Part no. KE550HS23

Generic cabling and cabling components standards - Category 6A cable requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- IEC 61156-5:2020 (Ed. 3.0)
- EN 50173-1:2018 / EN 50173-2:2018
- EN 50288-10-1:2012
- TIA-568.2-D:2018

Standards for flammability, halogen acidity, and smoke performance

- IEC 60332-1-1:2015 (Ed. 1.1) / IEC 60332-1-2:2015 (Ed. 1.1)
- IEC 60754-2:2019 (Ed. 2.1)
- IEC 61034-1:2019 (Ed. 3.2) / IEC 61034-2:2019 (Ed. 3.2)

Technical report

12322647, DANAK-19/23250

EC Cabling product ID


7307

CS valid until

1 February 2024

This product has been tested by FORCE Technology and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance schedule, which implies that FORCE Technology performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

Hørsholm, 6 February 2023



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department



Compliance Statement

No. 2023-130

Data communication cable, Category 7

Company

KRUGEL EXIM spol. s r.o.
Pri majeri 13
831 06 Bratislava
Slovak Republic

Product description

Screened cable (S/FTP) characterised up to 1000 MHz*
Horizontal floor wiring cable, 100 Ω
4 individually foil screened twisted pairs with overall braid screen
Flame retardant, halogen free

Product identification

Keline 10Giga 1000MHz, S/FTP 4x2xAWG23 Cat.7, LSOH
Part number: KE1000HS23

Generic cabling and cabling components standards - Category 7 cable requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- IEC 61156-5:2020 (Ed. 3.0)
- EN 50173-1:2018 / EN 50173-2:2018
- EN 50288-4-1:2013

Standards for flammability, halogen acidity, and smoke performance

- IEC 60332-1-1:2015 (Ed. 1.1) / IEC 60332-1-2:2015 (Ed. 1.1)
- IEC 60754-2:2019 (Ed. 2.1)
- IEC 61034-1:2019 (Ed. 3.2) / IEC 61034-2:2019 (Ed. 3.2)

Technical report

12322932, DANAK-19/23271

EC Cabling product ID

7463


CS valid until

1 March 2024

*Transmission parameters comply with extended Cat. 7 limits up to 1000 MHz.

This product has been tested by FORCE Technology and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance schedule, which implies that FORCE Technology performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

Hørsholm, 13 February 2023


Lars Lindskov Pedersen
Test Manager


Dennis Andersen
Head of Department



Compliance Statement

No. 2022-290

Connecting Hardware, Category 6A

Including 4 Pair Power over Ethernet (4PPoE)

(Un-mating connectors under electrical load of up to 2 A per conductor)

Company

KRUGEL EXIM spol. s r.o.
Rybníčná 38/H
831 06 Bratislava
Slovak Republic

Product description

Screened Category 6A RJ45 Jack and Patch Panel characterised up to 500 MHz, 100 Ω

Product identification

KELine RJ45 Jack. Part number: KEJ-C6A-S-10G

KELine Patch Panel. Part number: KEP-C6A-S-10G

KELine Patch Panel. Part number: KEP-C6A-S-10G-NP

Generic cabling and cabling components standards - Category 6A connector requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- IEC 60603-7-51:2010
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018
- IEC 60512-99-002:2022

including all connector alien crosstalk parameters (PS ANEXT and PS AFEXT)

Technical report

12226146, DANAK-19/22654

EC Cabling product ID


5113

CS valid until

1 June 2023

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The testing included measurement of NEXT with a compliant test plug and calculation of all the 14 test cases in both measurement directions. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis once a year.

Hørsholm, 3 May 2022


Lars Lindskov Pedersen
Test Manager


Dennis Andersen
Head of Department



Certificate

No. c7715d-22

Customer:

Krugel Exim spol. s r.o.
Pri majeri 13
831 06 Bratislava 35, Slovakia

Category 6A

Test sample(s):

Connecting hardware:
Keline® RJ-45 Keystone Cat.6A

Part no.: KEJ-C6A-S-HD

Applied standard(s):

ISO/IEC 11801-1 Ed.1.0 (2017-11)
IEC 60603-7-51 Ed.1.0 (2010-03)

Result(s):

The sample meets the limits of the specified standards and regulations with respect to the parameters indicated above.

Connecting hardware, Copper, Category 6A

GHMT Type Approval

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report no. **R7715d-22** and shall only be applicable in conjunction with the test report. This certificate is valid 24 months after date of testing.

Bexbach, 06.02.2023



Dirk Wilhelm, engineer
(Chairman of the Managing Board)



Test laboratory accredited by DAkkS in accordance with DIN EN ISO/IEC 17025:2018.
The accreditation is valid for the test methods listed in certificate **D-PL-17559-01-00**.

GHMT AG

In der Kolling 320
66450 Bexbach / Germany

P0 box 11 16
66442 Bexbach / Germany

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de

**RELIABILITY IN TOTAL
REQUIRES ACCURACY IN DETAIL.**

Compliance Statement

No. 2023-080

Data communication cords, Category 6A

Company

KRUGEL EXIM spol. s r.o.
Pri majeri 13
831 06 Bratislava
Slovak Republic

Product description

Screened Category 6A RJ45 cords (equipment, patch, and work area) characterised up to 500 MHz

Product identification

KELine 10Giga patch cables STP Cat.6A, LS0H
Part number: KEL-C6A-P-xxx (xxx: denotes length in dm)

Generic cabling and cabling components standard - Category 6A balanced cord requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018
- IEC 61935-2:2010 (Ed. 3.0) (transmission requirements)

Technical report

12233517-01, DANAK-19/23232

EC Cabling product ID


5008

CS valid until

1 March 2024

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 1 February 2023



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department

